

NSF International

789 N. Dixboro Road, Ann Arbor, MI 48105 USA

RECOGNIZES

Hain Yo Enterprises Co., Ltd.

Taiwan

AS COMPLYING WITH NSF/ANSI 61, 372 AND ALL APPLICABLE REQUIREMENTS.
PRODUCTS APPEARING IN THE NSF OFFICIAL LISTING ARE
AUTHORIZED TO BEAR THE NSF MARK.



ANSI Accredited Program
PRODUCT CERTIFICATION
#0216
Certification Program
Accredited by the
American National
Standards Institute



Standards Council of Canada
Certification Program
Accredited by the
Standards Council
of Canada

This certificate is the property of NSF International and must be returned upon request. This certificate remains valid as long as this client has products in Listing for the referenced standards. For the most current and complete Listing information, please access NSF's website (www.nsf.org).

A handwritten signature in black ink, appearing to read "David Purkiss".

February 22, 2016
Certificate# 1B720 - 02

David Purkiss
General Manager, Plumbing



OFFICIAL LISTING

NSF certifies that the products appearing on this Listing conform to the requirements of
NSF/ANSI/CAN 61 - Drinking Water System Components - Health Effects

This is the Official Listing recorded on May 27, 2025.

Hain Yo Enterprises Co., Ltd.
No. 102, Tien Tung Road
Ho-Mei, Changhua
Taiwan
886 4 757 4837

Facility: Changhua, Taiwan

Mechanical Plumbing Devices

Faucet Cartridges

AH01AJ ^[G] ^[Q]	AH03AJ ^[G] ^[Q]	DH02BD ^[1]	DH02GJ ^[1]	DH03DJ ^[1]
DH04BD ^[1]	DH04GJ ^[1]	DH06DD ^[1]	DH12TD ^[G] ^[Q]	DH16GJ ^[1]
DH17GJ ^[G] ^[Q]	DL02BD ^[1]	DL02GJ ^[1]	DL03DJ ^[1]	DL04BD ^[1]
DL04GJ ^[1]	DL05BJ ^[1]	DL06DD ^[1]	EH12TD ^[G] ^[Q]	FH02BD ^[1]
FH02GJ ^[1]	FH03DD ^[1]	FH03DJ ^[1]	FH04BD ^[1]	FH06DD ^[1]
FH12TD ^[G] ^[Q]	FH16GJ ^[1]	FH17GJ ^[Q]	FL02BD ^[1]	FL02GJ ^[1]
FL03DD ^[1]	FL03DJ ^[1]	FL04BD ^[1]	FL06DD ^[1]	FL12TD ^[Q]
FL19GJ ^[G] ^[Q]	GH02GJ ^[1]	GH16GJ ^[Q]	GL02BJ ^[1]	GL02GJ ^[1]
GL12TD ^[G] ^[Q]	WH16GJ ^[Q]			

[1] This product does not require a Q statistic. It is made from material or materials that do not require lead analysis when reviewed per NSF/ANSI/CAN Standard 61, Section 3.3.

[G] Product is Certified to NSF/ANSI 372 and conforms with the lead content requirements for "lead free" plumbing as defined by California, Vermont, Maryland, and Louisiana state laws and the U.S. Safe Drinking Water Act.

[Q] This product meets the reduced Q test statistic criteria of 1 µg or 0.5 µg for lead per Section 9.5.1.1 of NSF/ANSI/CAN 61.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF.

1 of 1

NSF International

789 N. Dixboro Road, Ann Arbor, MI 48105 USA

RECOGNIZES

Hain Yo Enterprises Co., Ltd.

Facility: Changhua, Taiwan

AS COMPLYING WITH NSF/ANSI 61, 372 AND ALL APPLICABLE REQUIREMENTS.
PRODUCTS APPEARING IN THE NSF OFFICIAL LISTING ARE
AUTHORIZED TO BEAR THE NSF MARK.



ANSI Accredited Program
PRODUCT CERTIFICATION
60216
Certification Program
Accredited by the
American National
Standards Institute



Certification Program
Accredited by the
Standards Council
of Canada

This certificate is the property of NSF International and must be returned upon request. This certificate remains valid as long as this client has products in Listing for the referenced standards. For the most current and complete Listing information, please access NSF's website (www.nsf.org).

A handwritten signature in black ink, appearing to read "David Purkiss".

February 22, 2016
Certificate# 1B721 - 02

David Purkiss
General Manager, Plumbing



OFFICIAL LISTING

NSF certifies that the products appearing on this Listing conform to the requirements of
NSF/ANSI 372 - Drinking Water System Components - Lead Content

This is the Official Listing recorded on December 16, 2022.

Hain Yo Enterprises Co., Ltd.
No. 102, Tien Tung Road
Ho-Mei, Changhua
Taiwan
886 4 757 4837

Facility: Changhua, Taiwan

Faucet Cartridges [Q] [LL]

AH01AJ AH03AJ DH12TD DH17GJ EH12TD FH12TD FL19GJ GL12TD

[Q] This product meets the reduced Q test statistic criteria of 1 µg or 0.5 µg for lead per Section 9.5.1.1 of NSF/ANSI/CAN 61.

[LL] Product conforms with lead content requirements for "lead free" plumbing as defined by California, Vermont, Maryland, and Louisiana state laws and the U.S. Safe Drinking Water Act.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF.

1 of 1